

# General Environmental Incident Summary

**Incident:** 4105      **Date/Time Notice:** 5/20/2016      1000      **DEM Incident No:**  
**Responsible Party:** Cass County Electric Cooperative  
**Date Incident:** 5/20/2016      **Time Incident:**      **Duration:** 3 hours  
**County:** Cass      **Twp:** 139      **Rng:** 49      **Sec:** 21      **Qtr:**  
**Lat:** 46.83591      **Long:** -96.87612      **Method:** Interpolation from map  
**Location Description:** Scheels Arena 5225 31 AVE S, Fargo ND

**Submitted By:** Jodi Bullinger      **Affiliation:** CCEC  
**Address:** 4100 32nd Ave S  
**City:** Fargo      **State:** ND      **Zip:** 58104

## Received By:

**Contact Person:** Jodi Bullinger  
4100 32nd Ave S  
Fargo, ND 58104

**Distance Nearest Occupied Building:** 30 Feet      **Release Contained:** Yes

**Type of Incident:** Vehicle Accident

**Description of Released Contaminant:** Transformer Non-PCB Mineral Oil

**Volume Spilled:** 10.00 gallons      **Ag Related:** No

**EPA Extremely Hazardous Substance:** Unknown      **Reported to NRC:** Unknown

## Cause of Incident:

Cass County Electric was dispatched to the Scheels Arena after a transformer was damaged during construction of their addition. It is unknown when the transformer was hit.

## Risk Evaluation:

Mineral oil in soil.

**# of Fatalities:** 0      **# of Injuries:** 0      **Affected Medium:** 03 - soil

## Potential Environmental Impacts:

none

## Action Taken or Planned:

Crew used absorbent materials to contain the spill and is currently removing the transformer from service. Per CCEC policy a sample of the oil will be sent in for testing to confirm NON-PCB status.

**Wastes Disposal Location:** Landfill if tests confirm NON-PCB status.

## Agencies Involved:

## ***Updates***

---

***Date:*** 5/20/2016    ***Status:*** Awaiting Documentation

***Author:*** Tintes Schiwal, Emily

***Updated Volume:***

***Notes:***

I spoke to Hunter Hubrig with Fargo Cass Public Health. He went by the site and said the release was contained, and there shouldn't be any concern of the oil migrating to water. I have requested clarifications, photos, and lab results from a representative at Cass County Electric Cooperative. I will update when I get more information.